



**COLOR CODE LEGEND**

- 8" (NOM.) REINF. CMU INTERIOR WALL TO 10'-0" ABOVE CONCRETE FLOOR SLAB. (TYPICAL, UNLESS NOTED).
  - 8" (NOM.) REINF. CMU INTERIOR WALL TO 12'-0" ABOVE CONCRETE FLOOR SLAB. (ROOF JOIST BEARING).
  - 8" (NOM.) REINF. CMU INTERIOR WALL TO 13'-4" ABOVE CONCRETE FLOOR SLAB. (APPARATUS ROOM SIDE WALLS. 1-HOUR FIRE-RATED, U. L. DESIGN # U405).
  - 8" (NOM.) REINF. CMU INTERIOR WALL TO ~12'-0" ABOVE CONCRETE FLOOR SLAB. (OXYGEN TANK STORAGE ROOM PERIMETER WALLS. 2-HOUR FIRE-RATED, U. L. DESIGN # U405).
  - 8" (NOM.) REINF. CMU INTERIOR WALL TO 10'-0" ABOVE CONCRETE FLOOR SLAB AND 3 5/8" METAL STUDS FROM TOP OF CMU TO UNDERSIDE OF ROOF DECK WITH ONE LAYER OF 5/8" TYPE-X GYP BOARD ON EACH SIDE. (1-HOUR FIRE-RATED BETWEEN DAYROOM AND BUNKROOM TOILETS, U.L. DESIGN # U405 TO 10'-0" ABOVE FLOOR AND U.L. DESIGN # U419 FROM TOP OF CMU TO ROOF DECK).
- NOTE: CONTRACTOR MAY OPT TO EXTEND CMU (U.L. DESIGN # U405 TO ROOF DECK) IN LIEU OF METAL STUDS AND GNB ABOVE 10'-0".

**EXTERIOR MAINTENANCE BAY NOTES**

THE TWO 22'-0" WIDE X 30'-0" DEEP RESTOCKING AND MAINTENANCE BAYS ARE BASE BID. BASE BID INCLUDES CONCRETE PAVEMENT AND CONCRETE CURBS. THE CONCRETE PAVEMENT SHALL BE MONOLITHIC AND SHALL SHEET FLOW TO THE NEAREST DROP INLET. (NOT AS DRAWN --THE TRENCH DRAINS INDICATED ARE NOT BASE BID).

AT THESE TWO BAYS, THE BRICK PIERS, SCREEN WALLS, STEEL PIPE BOLLARDS, STEEL COLUMNS, ROOF STRUCTURE AND ROOF PANELS ARE ADDITIVE BID ITEM #1. THE TWO 10'-0" LONG TRENCH DRAINS INDICATED ARE ALSO ADDITIVE BID ITEM #1.

BASE BID = NO ROOF STRUCTURE AND PAVEMENT TO SHEET FLOW TO NEAREST DROP INLET.

ADDITIVE BID ITEM #1 = ROOF COVERING AND TRENCH DRAINS. SLOPE CONCRETE TO TRENCH DRAINS AT 1/4" PER FOOT.

**FLOOR PLAN PARTITION TYPES + NOTATIONS**

SCALE: 1/8" = 1'-0"

FOR INTERIOR SIGNAGE LOCATIONS, SEE DRAWING A603

- PARTITION KEY NOTES**
- SEE DRAWING A501 FOR WALL AND PARTITION DETAILS.
- NOTES - A) ALL CMU SHALL BE RUNNING BOND WITH CONCAVE JOINTS.  
 B) BRICK VENEER SHALL BE RUNNING BOND WITH CONCAVE JOINTS, UNLESS NOTED OTHERWISE ON ELEVATIONS.  
 C) ALL GYPSUM WALLBOARD SHALL BE LEVEL 4 FINISH.
- ① PRE-ENGINEERED METAL BUILDING FRAMING WITH PREFINISHED INSULATED METAL WALL PANELS ON EXTERIOR. PREFINISHED METAL LINER PANELS ON INTERIOR FACE X 8'-0" HIGH.
  - ② 8" REINFORCED CMU EXTERIOR WALL. FOAMED INSULATION IN UNROUTED CELLS.
  - ③ 8" REINFORCED CMU EXTERIOR WALL. FOAMED INSULATION IN UNROUTED CELLS. INTERIOR FURRED WITH 3 5/8" METAL STUDS. UNFACED BATT INSULATION BETWEEN STUDS. 5/8" GNB ON INTERIOR FACE. 6NB WITH LEVEL 4 FINISH.
  - ④ 8" REINFORCED CMU EXTERIOR WALL. FOAMED INSULATION IN UNROUTED CELLS. BRICK VENEER ON EXTERIOR FACE.
  - ⑤ 8" REINFORCED CMU EXTERIOR WALL. FOAMED INSULATION IN UNROUTED CELLS. BRICK VENEER ON EXTERIOR FACE. INTERIOR FURRED WITH 3 5/8" X 20 GA. METAL STUDS WITH UNFACED BATT INSULATION BETWEEN STUDS. 5/8" GNB ON INTERIOR FACE. 6NB WITH LEVEL 4 FINISH.
  - ⑥ 8" REINFORCED CMU INTERIOR WALL.
  - ⑦ 4" CMU MET WALL.
  - ⑧ 3 5/8" X 20 GA. METAL STUDS WITH 5/8" GNB ON ONE SIDE. UNFACED SOUND ATTENUATION BLANKETS BETWEEN STUDS. 6NB WITH LEVEL 4 FINISH.
  - ⑨ 3 5/8" X 20 GA. METAL STUDS WITH 1/2" GEMENTICIOUS BACKER BOARD ON ONE SIDE, UNFACED SOUND ATTENUATION BLANKETS BETWEEN STUDS. FINISH WITH 3" X 12" WHITE HORIZONTAL SUBWAY TILE.
  - ⑩ 3 5/8" X 20 GA. METAL STUDS WITH 5/8" GNB ON BOTH SIDES. UNFACED SOUND ATTENUATION BLANKETS BETWEEN STUDS. 6NB WITH LEVEL 4 FINISH.
  - ⑪ 6" X 20 GA. METAL STUDS WITH 5/8" GNB ON BOTH SIDES, UNFACED SOUND ATTENUATION BLANKETS BETWEEN STUDS. 6NB WITH LEVEL 4 FINISH.



DATE	01-30-2026
NO.	REVISION DATE
1	
2	
3	
SHEET	A101
DRAWN BY	CHECKED BY
DMW	MRL
PROJECT NO.	TLG-2515
THE LANE GROUP INC	